



## **QUALITY CERTIFICATE**

Vessel Customer Operation

JADE STAR

SPRAGUE ENERGY

**ANALYSIS** 

Port Date

Terminal

PORTSMOUTH, NH

February 22, 2005

**SPRAGUE GOSLING RD** 

Report PL05-129

Reference

Sample # 892488

Name of material being tested Description of sample source Samples Drawn by (company) Samples Tested by (company)

## #6 FUEL OIL

TANK 2

**BSI-INSPECTORATE AMERICA BSI-INSPECTORATE AMERICA** 

Tests being Performed	Test method	Sample Results
GRAVITY, API	ASTM D 4052	11.4
LASH POINT, F.	ASTM D 93B	212+
SULPHUR, % WT. AVERAGE	ASTM D 4294	0.990
ISCOSITY, SSF, 122F	ASTM D 445/2161	163.3
POUR POINT, F.	ASTM D 97	+26.6
VATER BY DISTILLATION	ASTM D 95	0.05
VATER & SEDIMENT, % VOL.	ASTM D 1796	0.1
EDIMENT BY EXTRACTION	ASTM D 473	0.02
ੇH, % WT.	ASTM D 482	0.03
SPHALTINES, %WT	IP 143	2.78
TU'S PER POUND	ASTM D 4868	18,371
TU'S PER GALLON	CONVERSION	151,506
'ANADIUM, PPM	IP-470	20
SODIUM, PPM	IP-470	9
IITROGEN, %WT	ASTM D 5762	0.2554
CARBON RESIDUE % WT.	ASTM D 4530	10.60
SULPHUR, % WT.	ASTM D 4294	
92327	UPPER	0.986
92328	MIDDLE	0.988
92329	LOWER	0.995
BY SPRAGUE TO CUSTOMER. SPRAGUE I MERCHANTABILITY OR FITNESS FOR AN INTI SET FORTH IN WRITING IN ANY CONTRAC AND A BUYER OF PRODUCT. SPRAGUE ASS	THE PRODUCT AT THE SPRAGUE PECTION NOTED ON THE CERTIFICATE. STOMER FOR THE PURPOSE OF RIFIED PRODUCT SPECIFICATION ON MINAL SHORE TANK AS NOTED ON THE IS NOT TO BE USED FOR ANY OTHER BILITY FOR THE PRODUCT AFTER DELIVERY	